

Performance of the Generating Stations of RVUN for the Year 2008-09 & Year 2009-10 (Upto April)

PARTICULARS /PARAMETERS	STPS		KTPS		RGTPS		DCCPP		Mahi Hydel	
	Year 2008-09	Year 2009-10 (uptoApril)	Year 2008-09	Year 2009-10 (April'09)	Year 2008-09	Year 2009-10 (uptoApril)	Year 2008-09	Year 2009-10 (uptoApril)	Year 2008-09	Year 2009-10 (uptoApril)
Capacity (MW)	1250 MW	1250 MW	1045 MW	1045 MW	110.5 MW	110.5 MW	330 MW	330 MW	140 MW	140 MW
PLF (%)	88.96	91.62	94.76	98.92	36.00	37.59	79.17	86.55	9.25	0
Gross Generation (MU)	9740.61	824.585	8674.161	744.303	348.68	29.91	2288.77	205.644	113.48	0
Aux. Consumption (%)	9.19	9.06	9.37	9.42	9.55	8.66	2.61	2.65	0.57	0
Net Generation (MU)	8841.46	749.648	7856.302	673.731	315.37	27.32	2229.37	200.201	112.83	0
Sp. Oil Consumption (ml / Kwh)	0.77	0.7	0.434	0.178	0.827	0.921	NA	NA	NA	NA
Sp. Coal Consumption (Kg / Kwh)	0.669	0.634	0.674	0.715	NA	NA	NA	NA	NA	NA
Sp. Gas Consumption (SCM/ Kwh)	NA	NA	NA	NA	0.6016	0.7093	0.2271	0.2104	NA	NA
Cost of generation per KWH	3.11	3.19	2.27	2.3	2.74	2.75	2.05	2.05	1.34	0