

Performance of RRVUNL Power Stations for the Year 2011-12

All Figures in MU

Sl. No.	Name of Power Station	PLF %	Gross Generation	Aux. Consumption (%)	Net Generation	Specific Oil Consumption (ml/Kwh)	Specific Coal Consumption (Kg/Kwh)	Specific Gas Consumption (Scm/Kwh)
1	SSTPS	81.01	10674.33	8.79	9735.59	0.85	0.65
2	KSTPS	92.59	10084.78	9.59	9117.62	0.47	0.64
3	DCCPP	77.76	2254.14	2.73	2192.62	0.24
4	CTPP	70.50	2260.96	11.60	1998.74	3.15	0.66
5	GLTPP	22.24	488.29	21.20	384.75	2.24	1.18
6	RGTPP	55.30	536.79	1.78	527.21	0.04	0.55
7	MAHI HYDL	14.68	180.50	1.33	179.17
8	MMH HYDL	8.51	17.83	0.37	17.46
9	RPS	24.06	363.56	0.11	363.15
10	JS	31.91	277.50	0.09	277.19
	TOTAL		27138.68		24793.50			